



1537 Air Rail Avenue • Virginia Beach, VA 23455 • phone 757.460. 3381

CERTIFICATE OF COMPLIANCE

Aetna Insulated Wire, Inc. certifies that it's RHW-2 or USE-2 is manufactured and tested in the USA in a manner that assures compliance with the following specifications.

- UL 44 – File No. E63541
- UL 854 – File No. E63541
- CSA LL82214
- Rated RW90 per Canadian Standards C22.2 No. 38.
- Passes CSA's cold impact test at -40°C
- Cross – linked Polyethylene Insulation
- Sunlight Resistant
- For use in wet or dry locations at temperatures up to 90°C
- 1/0 and larger rated for use in Cable Trays
- ASTM – B3
- ASTM – B8
- ASTM – B787
- National Electric Code
- NEMA WC70/ICEA S-95-658

A handwritten signature in black ink, appearing to read "Rick Williamson", is written over a horizontal line.

Rick Williamson
Director of Engineering



A member of the Marmon Group of Companies